

FUEL TREATMENT MAP LEGEND

**Daley Ranch Resort
Escondido, CA**

Symbol	Description
NO COLOR	FUEL TREATMENT ZONE 1A (LOT OWNER MAINTAINED) - An irrigated zone beginning at the edge of each structure and includes the entire lot (front, back and sideyards) and is maintained to Zone 1A criteria. Zone 1A will be cleared of all existing native vegetation and replanted with drought tolerant, fire resistant and irrigated fire resistant lawns, ground covers and low growing shrubs (see written Fire Protection Plan for further information).
[Green Box]	FUEL TREATMENT ZONE 1B (HOA MAINTAINED) - Zone 1B is an irrigated zone that includes manufactured slopes and is maintained to Zone 1A criteria (see written Fire Protection Plan for further information).
[Red Box]	NO BUILD ZONE (LOT OWNER MAINTAINED) - The No Build Zone is 15 feet in width and has the same landscaping and maintenance requirements as Zone 1A. No combustible structures, which include the house, can be built within this zone (see written Fire Protection Plan for further information).
[Pink Box]	FUEL TREATMENT ZONE 2A (LOT OWNER MAINTAINED) - Non-irrigated thinning zone beginning at the outer edge of Zone 1B. The intent is to achieve and maintain an overall 50 percent reduction of the canopy cover spacing, a 50 percent reduction of the original fuel loading and the 100 percent removal of all dead and dying plant material. Native annual and perennial grasses will be allowed to grow and produce seed during the winter and spring. As grasses begin to cure (dry out), they will be cut to 4 inches or less in height. Each tree will be limbed to maintain a separation of 6 feet between the ground fuels (shrubs and ground covers) and the lower limbs (see written Fire Protection Plan for further information).
[Orange Box]	FUEL TREATMENT ZONE 2B (HOA MAINTAINED) - Non-irrigated zone thinning zone maintained to Zone 2A criteria (see written Fire Protection Plan for further information).
[Blue Box]	FUEL TREATMENT ZONE 3 (HOA MAINTAINED) - This zone includes areas disturbed by grading and will be planted and temporarily irrigated until such time as the plants are established. Maintenance will then be consistent with Zone 2A (see written Fire Protection Plan for further information).
[Purple Box]	ROADSIDE TREATMENT - 20 feet on either side of the fire access roads cleared of all vegetation or planted and maintained to Zone 1B criteria (see written Fire Protection Plan for further information).
[Grey Box]	ADJACENT FUEL MODIFICATION - 100 feet of fuel modifications on existing nearby properties.
[Dashed Line]	NON-COMBUSTIBLE WALL - 6 foot high non-combustible wall located on subdivision boundary.

Certified By

 Ronald J. Woychak, President Date: 01/10/2018

FIREWISE 2000, Inc.
 1320 Scenic Drive
 Escondido, CA 92029
 Telephone: 760-745-3947
 firewise2000@sbcglobal.net

